



### G83/2 Appendix 4 Type Verification Test Report

Type Approval and manufacturer/supplier declaration of compliance with the requirements of Engineering Recommendation G83/2.			
SSEG Type reference number		IQ7-60-2-INT, IQ7-60-5-INT, IQ7-60-ACM-INT	
SSEG Type		Microinverter	
System Supplier name		Enphase Energy Inc	
Address		1 Treffers Rd, Wigram Christchurch, 8042 New Zealand	
Tel	+64-3-345 5339	Fax	
E:mail	dkeis@enphaseenergy.com	Web site	www.enphase.com
Maximum rated capacity, use separate sheet if more than one connection option.	Connection Option		
	≤ 3.68	kW single phase, single, split or three phase system	
		kW three phase	
		kW two phases in three phase system	
		kW two phases split phase system	
<p>SSEG manufacturer/supplier declaration.</p> <p>I certify on behalf of the company named above as a manufacturer/supplier of Small Scale Embedded Generators, that all products manufactured/supplied by the company with the above SSEG Type reference number will be manufactured and tested to ensure that they perform as stated in this Type Verification Test Report, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of G83/2.</p>			
Signed		On behalf of	
<p>Note that testing can be done by the manufacturer of an individual component, by an external test house, or by the supplier of the complete system, or any combination of them as appropriate. Where parts of the testing are carried out by persons or organisations other than the supplier then the supplier shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.</p>			

**Power Quality. Harmonics.** The requirement is specified in section 5.4.1, test procedure in Annex A or B 1.4.1

SSEG rating per phase (rpp)				2.16	kW			NV=MV*3.68/rpp	
Harmonic	50%	of rated output		100%	of rated output				
	Measured Value (MV) in Amps	Normalised Value (NV) in Amps	P or F	Measured Value (MV) in Amps	Normalised Value (NV) in Amps	P or F	Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above	
2	0.0815	0.1389	P	0.0085	0.0145	P	1.08		
3	0.1425	0.2428	P	0.0542	0.0923	P	2.3		
4	0.0453	0.0772	P	0.0011	0.0019	P	0.43		
5	0.0312	0.0532	P	0.2776	0.4729	P	1.14		
6	0.0269	0.0458	P	0.0005	0.0009	P	0.3		
7	0.0216	0.0368	P	0.0284	0.0484	P	0.77		
8	0.0146	0.0249	P	0.0004	0.0007	P	0.23		
9	0.0115	0.0196	P	0.0246	0.0419	P	0.4		
10	0.0094	0.0160	P	0.0006	0.0010	P	0.184		
11	0.0100	0.0170	P	0.0244	0.0416	P	0.33		
12	0.0117	0.0199	P	0.0006	0.0010	P	0.153		
13	0.0117	0.0199	P	0.0133	0.0227	P	0.21		
14	0.0070	0.0119	P	0.0008	0.0014	P	0.131		
15	0.0060	0.0102	P	0.0163	0.0278	P	0.15		
16	0.0067	0.0114	P	0.0005	0.0009	P	0.115		
17	0.0055	0.0094	P	0.017	0.0290	P	0.132		
18	0.0035	0.0060	P	0.0008	0.0014	P	0.102		
19	0.0057	0.0097	P	0.0089	0.0152	P	0.118		
20	0.0030	0.0051	P	0.0009	0.0015	P	0.092		
21	0.0042	0.0072	P	0.0173	0.0295	P	0.107	0.16	
22	0.0003	0.0005	P	0.0005	0.0009	P	0.084		
23	0.0004	0.0007	P	0.0076	0.0129	P	0.098	0.147	
24	0.0005	0.0009	P	0.0006	0.0010	P	0.077		
25	0.0006	0.0010	P	0.0105	0.0179	P	0.09	0.135	
26	0.0005	0.0009	P	0.0005	0.0009	P	0.071		
27	0.0004	0.0007	P	0.0097	0.0165	P	0.083	0.124	
28	0.0003	0.0005	P	0.0006	0.0010	P	0.066		
29	0.0004	0.0007	P	0.004	0.0068	P	0.078	0.117	
30	0.0007	0.0012	P	0.0005	0.0009	P	0.061		
31	0.0003	0.0005	P	0.0082	0.0140	P	0.073	0.109	
32	0.0003	0.0005	P	0.0005	0.0009	P	0.058		
33	0.0004	0.0007	P	0.0082	0.0140	P	0.068	0.102	
34	0.0004	0.0007	P	0.0006	0.0010	P	0.054		
35	0.0004	0.0007	P	0.0046	0.0078	P	0.064	0.096	
36	0.0004	0.0007	P	0.0007	0.0012	P	0.051		
37	0.0004	0.0007	P	0.0085	0.0145	P	0.061	0.091	
38	0.0004	0.0007	P	0.0006	0.0010	P	0.048		
39	0.0005	0.0009	P	0.0063	0.0107	P	0.058	0.087	
40	0.0018	0.0031	P	0.002	0.0034	P	0.046		

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

<b>Power Quality. Voltage fluctuations and Flicker.</b> The requirement is specified in section 5.4.2, test procedure in Annex A or B 1.4.3								
	Starting			Stopping			Running	
	$d_{max}$	dc	d(t)	$d_{max}$	dc	d(t)	$P_{st}$	$P_{it}$ 2 hours
Measured Values	0.22	0.22	0	0.19	0.18	0	0.12	0.11
Normalised to standard impedance and 3.68kW for multiple units	0.120	0.120	0.000	0.103	0.098	0.000	0.065	0.060
Limits set under BS EN 61000-3-2	4%	3.30%	3.3% 500ms	4%	3.30%	3.3% 500ms	1	0.65
Test start date		10-Nov-17		Test end date		10-Nov-17		
Test location		1 Treffers Rd, Wigram, Christchurch, NZ						

<b>Power quality. DC injection.</b> The requirement is specified in section 5.5, test procedure in Annex A or B 1.4.4				
Test power level	10%	55%	100%	
Recorded value	0.0021	0.0008	0.0023	
as % of rated AC current	0.191%	0.015%	0.026%	
Limit	0.25%	0.25%	0.25%	

<b>Power Quality. Power factor.</b> The requirement is specified in section 5.6, test procedure in Annex A or B 1.4.2				
	216.2 V	230 V	253 V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.
Measured value	0.999	0.998	0.997	
Limit	>0.95	>0.95	>0.95	

<b>Protection. Frequency tests</b> The requirement is specified in section 5.3.1, test procedure in Annex A or B 1.3.3						
Function	Setting		Trip test		"No trip tests"	
	Frequency	Time delay	Frequency	Time delay	Frequency /time	Confirm no trip
U/F stage 1	47.5 Hz	20 s	47.53 Hz	20.3 s	47.7 Hz 25 s	Confirmed
U/F stage 2	47 Hz	0.5 s	47.05 Hz	0.65 s	47.2 Hz 19.98 s	Confirmed
					46.8 Hz 0.48 s	Confirmed
O/F stage 1	51.5 Hz	90 s	51.47 Hz	90.24 s	51.3 Hz 95 s	Confirmed
O/F stage 2	52 Hz	0.5 s	51.97 Hz	0.6 s	51.8 Hz 89.98 s	Confirmed
					52.2 Hz 0.48 s	Confirmed

**Protection. Voltage tests** The requirement is specified in section 5.3.1, test procedure in Annex A or B 1.3.2

Function	Setting		Trip test		"No trip tests"	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V stage 1	200.1 V	2.5 s	199.2 V	2.57 s	204.1 V 3.5 s	Confirmed
U/V stage 2	184 V	0.5 s	183.0 V	0.57 s	188 V 2.48 s	Confirmed
					180 V 0.48 s	Confirmed
O/V stage 1	262.2 V	1.0 s	262.4 V	1.07 s	258.2 V 2.0 s	Confirmed
O/V stage 2	273.7 V	0.5 s	274.0 V	0.57 s	269.7 V 0.98 s	Confirmed
					277.7 V 0.48 s	Confirmed

Note for Voltage tests the Voltage required to trip is the setting  $\pm 3.45$  V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting  $\pm 4$  V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

<b>Protection. Loss of Mains test.</b> The requirement is specified in section 5.3.2, test procedure in Annex A or B 1.3.4						
To be carried out at three output power levels with a tolerance of plus or minus 5% in Test Power levels.						
Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of SSEG output	95% of SSEG output	95% of SSEG output	105% of SSEG output	105% of SSEG output	105% of SSEG output
Trip time. Limit is 0.5 seconds	*5.9 ms	4 ms	4.1 ms	*6.8 ms	4.7 ms	6.9 ms
For Multi phase SSEGs confirm that the device shuts down correctly after the removal of a single fuse as well as operation of all phases.						
Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of SSEG output	95% of SSEG output	95% of SSEG output	105% of SSEG output	105% of SSEG output	105% of SSEG output
Trip time. Ph1 fuse removed	*151 ms	220 ms	384 ms	*142 ms	233 ms	222 ms
Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of SSEG output	95% of SSEG output	95% of SSEG output	105% of SSEG output	105% of SSEG output	105% of SSEG output
Trip time. Ph2 fuse removed	*157 ms	217 ms	210 ms	*153 ms	242 ms	231 ms
Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of SSEG output	95% of SSEG output	95% of SSEG output	105% of SSEG output	105% of SSEG output	105% of SSEG output
Trip time. Ph3 fuse removed	*141 ms	221 ms	213 ms	*158 ms	223 ms	210 ms
Note for technologies which have a substantial shut down time this can be added to the 0.5 seconds in establishing that the trip occurred in less than 0.5s. Maximum shut down time could therefore be up to 1.0 seconds for these technologies.						
Indicate additional shut down time included in above results.					0 ms	
Note as an alternative, inverters can be tested to BS EN 62116. The following sub set of tests should be recorded in the following table.						
Test Power and imbalance	33% -5% Q Test 22	66% -5% Q Test 12	100% -5% P Test 5	33% +5% Q Test 31	66% +5% Q Test 21	100% +5% P Test 10
Trip time. Limit is 0.5s	108 ms	173 ms	188 ms	102 ms	172 ms	184 ms

\*-Tested at 25%. It is not possible to test at 10% since the PCUs operate in a burst mode below 25%.

**Protection. Frequency change, Stability test** The requirement is specified in section 5.3.3, test procedure in Annex A or B 1.3.6

	Start Frequency	Change	End Frequency	Confirm no trip
Positive Vector Shift	49.5 Hz	+12 degrees		Confirmed
Negative Vector Shift	50.5 Hz	- 12 degrees		Confirmed
Positive Frequency drift	49.5 Hz	+0.2 Hz/sec	51.5 Hz	Confirmed
Negative Frequency drift	50.5 Hz	-0.2 Hz/sec	47.5 Hz	Confirmed

**Protection. Re-connection timer.** The requirement is specified in section 5.3.4, test procedure in Annex A or B 1.3.5

Test should prove that the reconnection sequence starts after a minimum delay of 20 seconds for restoration of voltage and frequency to within the stage 1 settings of table 1.

Time delay setting	Measured delay		Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.			
20s	27s		At 266.2 V	At 196.1 V	At 47.4 Hz	At 51.6 Hz
Confirmation that the SSEG does not re-connect.			Confirmed	Confirmed	Confirmed	Confirmed

**Fault level contribution.** The requirement is specified in section 5.7, test procedure in Annex A or B 1.4.6

For a directly coupled SSEG			For a Inverter SSEG		
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	$i_p$	3.22	20ms	0	0
Initial Value of aperiodic current	A	1.93	100ms	0	0
Initial symmetrical short-circuit current*	$I_k$	5.1	250ms	0	0
Decaying (aperiodic) component of short circuit current*	$i_{DC}$	0	500ms	0	0
Reactance/Resistance Ratio of source*	X/R	2.5	Time to trip	0.01	In seconds

**Self-Monitoring solid state switching** The requirement is specified in section 5.3.1, No specified test requirements.

Yes/or NA

It has been verified that in the event of the solid state switching device failing to disconnect the SSEG, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 seconds.

Yes

**Additional comments**

--