



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **SolarEdge Technologies Ltd.**
1 HaMada Street
Herzeliya 4673335
Israel

Product: **Grid-tied photovoltaic (PV) inverter**

Model: **SE25k
SE27.6K**

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G99/1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

Applied rules and standards:

Engineering Recommendation G99/1-3:2018

Requirements for the connection of generation equipment in parallel with public distribution networks

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: **14TH0476-G99/1_1**
Certificate number: **U19-0301**
Date of issue: **2019-05-17**

Certification body



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Type Approval and declaration of compliance with the requirements of Engineering Recommendation G99			
PGM Technology	Photovoltaic inverter		
Manufacturer:	SolarEdge Technologies Ltd.		
Address	1 HaMada Street Herzeliya 4673335 Israel		
Tel	+972-9-957-6620	Fax	+972-9-957-6591
Email	info@solaredge.com	Website	www.solaredge.com
Rated values	SE25K	SE27.6K	
Maximum rated capacity	25000W	27600W	
Rated voltage	230 / 400 3 wires, N, PE		
Firmware version	Main DSP software version is 1.130 Aux DSP software version is 2.19		
Measurement period:	2017-06-14 to 2017-06-29, 2019-01-10 to 2019-02-05, 2019-05-16		
Description of the structure of the power generation unit:			
The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.			
Differences between Generating Units:			
The inverters SE27.6K is based on the inverter SE25K. They use the same control unit, control system and software.			
The above stated Generating Units are tested according the requirements in the Engineering Recommendation G99/1. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the Engineering Recommendation G99/1.			

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Operating Range.	
Test 1	Voltage = 85% of nominal (195,5 V) Frequency = 47 Hz Power Factor = 1 Period of test 20 s
Connection:	Always connected
Limit:	Always connected
Test 1	Voltage = 85% of nominal (195,5 V) Frequency = 47.5 Hz Power Factor = 1 Period of test 90 minutes
Connection:	Always connected
Limit:	Always connected
Test 1	Voltage = 110% of nominal (253 V) Frequency = 51.5 Hz Power Factor = 1 Period of test 90 minutes
Connection:	Always connected
Limit:	Always connected
Test 1	Voltage = 110% of nominal (253 V) Frequency = 52.0 Hz Power Factor = 1 Period of test 15 minutes
Connection:	Always connected
Limit:	Always connected

Protection. Voltage tests.						
Phase 1						
Function	Setting		Trip test		No trip test	
	Voltage [V]	Time delay [s]	Voltage [V]	Time delay [s]	Voltage / time	Confirm no trip
U/V	184	2,5	184,1	2,782	188V / 3,5s	No trip
					180V / 2,48s	No trip
O/V stage 1	262,2	1,0	261,5	1,255	258,2V 2,0s	No trip
O/V stage 2	273,7	0,5	273,1	0,761	269,7V 0,98s	No trip
					277,7V 0,48s	No trip

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Protection. Voltage tests.						
Phase 2						
Function	Setting		Trip test		No trip test	
	Voltage [V]	Time delay [s]	Voltage [V]	Time delay [s]	Voltage / time	Confirm no trip
U/V	184	2,5	184,1	2,748	188V / 3,5s	No trip
					180V / 2,48s	No trip
O/V stage 1	262,2	1,0	261,5	1,261	258,2V 2,0s	No trip
O/V stage 2	273,7	0,5	273,1	0,748	269,7V 0,98s	No trip
					277,7V 0,48s	No trip

Protection. Voltage tests.						
Phase 3						
Function	Setting		Trip test		No trip test	
	Voltage [V]	Time delay [s]	Voltage [V]	Time delay [s]	Voltage / time	Confirm no trip
U/V	184	2,5	184,0	2,755	188V / 3,5s	No trip
					180V / 2,48s	No trip
O/V stage 1	262,2	1,0	261,5	1,255	258,2V 2,0s	No trip
O/V stage 2	273,7	0,5	273,2	0,755	269,7V 0,98s	No trip
					277,7V 0,48s	No trip

Note. For Voltage tests the Voltage required to trip is the setting $\pm 3,45V$. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting $\pm 4V$ and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Protection. Frequency tests.						
Function	Setting		Trip test		No trip test	
	Frequency [Hz]	Time delay [s]	Frequency [Hz]	Time delay [s]	Frequency / time	Confirm no trip
U/F stage 1	47,5	20	47,50	20,270	47,7Hz / 25s	No trip
U/F stage 2	47	0,5	47,00	0,785	47,2Hz / 19,98s	No trip
					46,8Hz / 0,48s	No trip
O/F stage 2	52	0,5	52,00	0,762	51,8Hz / 89,98s	No trip
					52,2Hz / 0,48s	No trip

Note. For Frequency Trip tests the Frequency required to trip is the setting $\pm 0,1$ Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The "No-trip tests" need to be carried out at the setting $\pm 0,2$ Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Protection. Loss of Mains.						
SE25K						
Inverters tested according to BS EN 62116.						
Balancing load on islanded network	33% of -5% Q Test 22	66% of -5% Q Test 12	100% of -5% P Test 5	33% of +5% Q Test 31	66% of +5% Q Test 21	100% of +5% P Test 10
Trip time. Ph1 fuse removed [s]	0,217	0,035	0,325	0,043	0,096	0,115
Trip time. Ph2 fuse removed [s]	0,217	0,035	0,325	0,043	0,096	0,115
Trip time. Ph3 fuse removed [s]	0,217	0,035	0,325	0,043	0,096	0,115
SE27.6K						
Inverters tested according to BS EN 62116.						
Balancing load on islanded network	33% of -5% Q Test 22	66% of -5% Q Test 12	100% of -5% P Test 5	33% of +5% Q Test 31	66% of +5% Q Test 21	100% of +5% P Test 10
Trip time. Ph1 fuse removed [s]	0,450	0,426	0,090	0,170	0,096	0,270
Trip time. Ph1 fuse removed [s]	0,450	0,426	0,090	0,170	0,096	0,270
Trip time. Ph1 fuse removed [s]	0,450	0,426	0,090	0,170	0,096	0,270

Note. Trip time limit is 0,5s. For technologies which have a substantial shut down time this can be added to the 0,5s in establishing that the trip occurred in less than 0,5s maximum. Shut down time could therefore be up to 1,0s for these technologies.

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Protection. Re-connection timer.				
Test should prove that the reconnection sequence starts in no less than 20 seconds for restoration of voltage and frequency to within the stage 1 settings of table 10.5.7.1.				
Under Voltage (182V)				
Time delay setting		Measured delay		
20s		37,0s		
Over Voltage (266,2V)				
Time delay setting		Measured delay		
20s		35,0s		
Under Frequency(47,4Hz)				
Time delay setting		Measured delay		
20s		34,0		
Over Frequency(52,1Hz)				
Time delay setting		Measured delay		
20s		35,0		
		Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.		
	At 266,2V	At 196,1V	At 47,4Hz	At 52,1Hz
Confirmation that the Generating Unit does not re-connect.	No reconnection	No reconnection	No reconnection	No reconnection

Protection. Frequency change, Stability test.				
	Start Frequency [Hz]	Change	Test Duration	Confirm no trip
Positive Vector Shift	49,5	+50 degrees		No trip
Negative Vector Shift	50,5	-50 degrees		No trip
Positive Frequency drift	49,0 to 51,0	+0,95Hz/sec	2,1s	No trip
Negative Frequency drift	51,0 to 49,0	-0,95Hz/sec	2,1s	No trip

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Limited Frequency Sensitive Mode – Over Frequency							
1-min mean value [Hz]:	a) 50,00	b) 50,45	c) 50,70	d) 51,15	e) 50,70	f) 50,45	g) 50,00
1. Measurement a) to g): Active power output > 80% P _n							
Frequency [Hz]:	50,00	50,45	50,70	51,15	50,70	50,45	50,00
P _M [kW]:	N/A	27,56	25,81	22,67	25,81	27,56	N/A
P _{E60} [kW]:	27,91	27,53	25,79	22,66	25,78	27,47	27,81
ΔP _{E60} /P _M [%]:	N/A	-0,03	-0,02	-0,01	-0,03	-0,09	N/A
2. Measurement a) to g): Active power output 40% and 60% after freezing > 80% P _n							
Frequency [Hz]:	50,00	50,45	50,70	51,15	50,70	50,45	50,00
P _M [kW]:	N/A	14,00	13,11	11,52	13,11	14,00	N/A
P _{E60} [kW]:	14,18	14,06	13,17	11,57	13,17	14,06	15,34
ΔP _{E60} /P _M [%]:	N/A	0,07	0,06	0,00	0,06	0,06	N/A
Limit ΔP/P _{1min} :	+ 10 % of P _M						
Note:							
The test was performed with a droop of 8% (25%P _n /Hz). The default droop setting 8% and is adjustable in the range between 2% and 10% at intervals of 1%.							

Output Power with falling Frequency			
5-min mean value (each)	a) 50 ± 0,01 Hz	b) - 0,4 to - 0,5 Hz	c) - 2,4 to - 2,5 Hz
Frequency [Hz]:	50,00	49,55	47,55
Active power [W]:	28666	28680	28703
ΔP/PM [%] per 1 Hz:			0



BUREAU
VERITAS

Annex to the G99/1 certificate of compliance No. U19-0301

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Power Quality. Harmonics.						
SE25K						
Phase 1						
SSEG rating per phase (rpp)						
	At 45-55% of rated output 4,13kW		100% of rated output 8,33kW			
Harmonic	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Harmonic %	
					Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,107	0,299	0,043	0,121	8%	8%
3rd	0,220	0,611	0,090	0,251	21,6%	N/A
4th	0,116	0,323	0,062	0,172	4%	4%
5th	0,304	0,845	0,434	1,209	10,7%	10,7%
6th	0,041	0,113	0,026	0,072	2,67%	2,67%
7th	0,135	0,376	0,321	0,894	7,2%	7,2%
8th	0,019	0,054	0,013	0,035	2%	2%
9th	0,014	0,038	0,018	0,051	3,8%	N/A
10th	0,015	0,043	0,010	0,029	1,6%	1,6%
11th	0,107	0,299	0,166	0,463	3,1%	3,1%
12th	0,018	0,050	0,011	0,031	1,33%	1,33%
13th	0,109	0,304	0,137	0,382	2%	2%
14th	0,016	0,046	0,010	0,028	N/A	N/A
15th	0,018	0,051	0,007	0,020	N/A	N/A
16th	0,010	0,028	0,006	0,018	N/A	N/A
17th	0,063	0,177	0,057	0,158	N/A	N/A
18th	0,009	0,026	0,006	0,016	N/A	N/A
19th	0,076	0,212	0,046	0,129	N/A	N/A
20th	0,013	0,037	0,006	0,018	N/A	N/A
21th	0,015	0,041	0,006	0,016	N/A	N/A
22th	0,009	0,024	0,006	0,017	N/A	N/A
23th	0,047	0,132	0,036	0,100	N/A	N/A
24th	0,005	0,014	0,005	0,013	N/A	N/A
25th	0,054	0,149	0,041	0,114	N/A	N/A
26th	0,008	0,023	0,006	0,016	N/A	N/A
27th	0,009	0,025	0,006	0,016	N/A	N/A
28th	0,006	0,017	0,005	0,015	N/A	N/A
29th	0,035	0,098	0,035	0,098	N/A	N/A
30th	0,004	0,010	0,004	0,010	N/A	N/A
31th	0,037	0,102	0,035	0,098	N/A	N/A
32th	0,005	0,014	0,005	0,014	N/A	N/A
33th	0,005	0,014	0,003	0,009	N/A	N/A
34th	0,004	0,012	0,005	0,014	N/A	N/A
35th	0,026	0,073	0,025	0,069	N/A	N/A
36th	0,004	0,011	0,003	0,009	N/A	N/A
37th	0,026	0,071	0,021	0,059	N/A	N/A
38th	0,005	0,013	0,005	0,014	N/A	N/A
39th	0,003	0,008	0,004	0,012	N/A	N/A
40th	0,004	0,012	0,005	0,013	N/A	N/A
THD	3,34%		1,34%		23%	13%
PWHD	0,007%		0,003%		23%	22%

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99 Nr. 14TH0476-G99/1_1

Power Quality. Harmonics.						
SE25K						
Phase 2						
SSEG rating per phase (rpp)						
	At 45-55% of rated output 4,13kW		100% of rated output 8,33kW			
Harmonic	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Harmonic %	
					Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,061	0,172	0,125	0,352	8%	8%
3rd	0,189	0,531	0,299	0,839	21,6%	N/A
4th	0,036	0,101	0,097	0,274	4%	4%
5th	0,421	1,184	0,258	0,724	10,7%	10,7%
6th	0,030	0,085	0,056	0,159	2,67%	2,67%
7th	0,351	0,987	0,183	0,515	7,2%	7,2%
8th	0,014	0,038	0,018	0,049	2%	2%
9th	0,072	0,202	0,074	0,207	3,8%	N/A
10th	0,011	0,031	0,014	0,040	1,6%	1,6%
11th	0,194	0,544	0,116	0,327	3,1%	3,1%
12th	0,012	0,035	0,014	0,040	1,33%	1,33%
13th	0,138	0,388	0,142	0,400	2%	2%
14th	0,008	0,022	0,010	0,027	N/A	N/A
15th	0,018	0,049	0,016	0,044	N/A	N/A
16th	0,010	0,027	0,012	0,033	N/A	N/A
17th	0,061	0,172	0,100	0,280	N/A	N/A
18th	0,007	0,020	0,016	0,044	N/A	N/A
19th	0,043	0,120	0,062	0,174	N/A	N/A
20th	0,006	0,018	0,009	0,025	N/A	N/A
21th	0,007	0,020	0,013	0,036	N/A	N/A
22th	0,006	0,016	0,011	0,032	N/A	N/A
23th	0,040	0,112	0,059	0,164	N/A	N/A
24th	0,005	0,014	0,011	0,032	N/A	N/A
25th	0,035	0,099	0,039	0,109	N/A	N/A
26th	0,006	0,017	0,008	0,022	N/A	N/A
27th	0,010	0,028	0,012	0,032	N/A	N/A
28th	0,005	0,015	0,009	0,026	N/A	N/A
29th	0,033	0,093	0,036	0,100	N/A	N/A
30th	0,005	0,013	0,007	0,020	N/A	N/A
31th	0,033	0,094	0,030	0,083	N/A	N/A
32th	0,005	0,014	0,006	0,017	N/A	N/A
33th	0,005	0,013	0,006	0,017	N/A	N/A
34th	0,005	0,013	0,006	0,018	N/A	N/A
35th	0,025	0,069	0,029	0,080	N/A	N/A
36th	0,004	0,010	0,004	0,012	N/A	N/A
37th	0,022	0,063	0,024	0,066	N/A	N/A
38th	0,005	0,014	0,006	0,016	N/A	N/A
39th	0,003	0,008	0,003	0,008	N/A	N/A
40th	0,004	0,013	0,005	0,015	N/A	N/A
THD	3,61%		1,49%		23%	13%
PWHD	0,007%		0,004%		23%	22%



Annex to the G99/1 certificate of compliance No. U19-0301

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99 Nr. 14TH0476-G99/1_1

Power Quality. Harmonics.						
SE25K						
Phase 3						
SSEG rating per phase (rpp)						
	At 45-55% of rated output 4,13kW		100% of rated output 8,33kW			
Harmonic	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Harmonic %	
					Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,060	0,168	0,126	0,352	8%	8%
3rd	0,171	0,478	0,338	0,944	21,6%	N/A
4th	0,050	0,140	0,114	0,318	4%	4%
5th	0,388	1,082	0,215	0,601	10,7%	10,7%
6th	0,051	0,142	0,092	0,256	2,67%	2,67%
7th	0,342	0,955	0,200	0,557	7,2%	7,2%
8th	0,018	0,049	0,024	0,068	2%	2%
9th	0,034	0,094	0,029	0,080	3,8%	N/A
10th	0,012	0,035	0,018	0,050	1,6%	1,6%
11th	0,175	0,489	0,127	0,355	3,1%	3,1%
12th	0,020	0,056	0,028	0,078	1,33%	1,33%
13th	0,128	0,356	0,113	0,316	2%	2%
14th	0,012	0,034	0,016	0,044	N/A	N/A
15th	0,015	0,041	0,032	0,089	N/A	N/A
16th	0,010	0,027	0,015	0,041	N/A	N/A
17th	0,062	0,173	0,090	0,252	N/A	N/A
18th	0,009	0,025	0,022	0,061	N/A	N/A
19th	0,041	0,115	0,073	0,204	N/A	N/A
20th	0,007	0,020	0,011	0,030	N/A	N/A
21th	0,008	0,023	0,025	0,070	N/A	N/A
22th	0,006	0,016	0,014	0,038	N/A	N/A
23th	0,046	0,128	0,065	0,181	N/A	N/A
24th	0,007	0,018	0,014	0,040	N/A	N/A
25th	0,042	0,117	0,053	0,147	N/A	N/A
26th	0,007	0,020	0,006	0,017	N/A	N/A
27th	0,009	0,025	0,015	0,043	N/A	N/A
28th	0,007	0,020	0,010	0,028	N/A	N/A
29th	0,042	0,116	0,043	0,119	N/A	N/A
30th	0,005	0,014	0,007	0,020	N/A	N/A
31th	0,037	0,104	0,039	0,110	N/A	N/A
32th	0,005	0,015	0,005	0,013	N/A	N/A
33th	0,005	0,013	0,008	0,022	N/A	N/A
34th	0,005	0,015	0,006	0,017	N/A	N/A
35th	0,028	0,077	0,029	0,082	N/A	N/A
36th	0,003	0,009	0,004	0,011	N/A	N/A
37th	0,022	0,061	0,028	0,078	N/A	N/A
38th	0,005	0,015	0,005	0,014	N/A	N/A
39th	0,004	0,011	0,004	0,010	N/A	N/A
40th	0,005	0,015	0,005	0,013	N/A	N/A
THD	2,28%		1,11%		23%	13%
PWHD	0,007%		0,003%		23%	22%

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99 Nr. 14TH0476-G99/1_1

Power Quality. Harmonics.						
SE27.6K						
Phase 1						
SSEG rating per phase (rpp)						
	At 45-55% of rated output 4,61kW		100% of rated output 8,81kW			
Harmonic	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Harmonic %	
					Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,037	0,098	0,042	0,111	8%	8%
3rd	0,058	0,154	0,108	0,287	21,6%	N/A
4th	0,046	0,123	0,068	0,181	4%	4%
5th	0,388	1,030	0,284	0,754	10,7%	10,7%
6th	0,017	0,046	0,011	0,030	2,67%	2,67%
7th	0,309	0,821	0,154	0,408	7,2%	7,2%
8th	0,010	0,026	0,013	0,036	2%	2%
9th	0,009	0,025	0,008	0,022	3,8%	N/A
10th	0,011	0,028	0,014	0,038	1,6%	1,6%
11th	0,168	0,447	0,121	0,322	3,1%	3,1%
12th	0,010	0,025	0,008	0,020	1,33%	1,33%
13th	0,150	0,397	0,116	0,308	2%	2%
14th	0,008	0,022	0,010	0,025	N/A	N/A
15th	0,006	0,015	0,005	0,014	N/A	N/A
16th	0,006	0,015	0,008	0,021	N/A	N/A
17th	0,070	0,186	0,075	0,198	N/A	N/A
18th	0,005	0,014	0,006	0,015	N/A	N/A
19th	0,060	0,158	0,080	0,212	N/A	N/A
20th	0,005	0,014	0,007	0,020	N/A	N/A
21th	0,004	0,010	0,004	0,011	N/A	N/A
22th	0,005	0,014	0,005	0,014	N/A	N/A
23th	0,038	0,101	0,052	0,139	N/A	N/A
24th	0,004	0,010	0,004	0,011	N/A	N/A
25th	0,036	0,096	0,055	0,146	N/A	N/A
26th	0,005	0,013	0,006	0,015	N/A	N/A
27th	0,004	0,010	0,005	0,012	N/A	N/A
28th	0,004	0,012	0,004	0,012	N/A	N/A
29th	0,031	0,083	0,037	0,098	N/A	N/A
30th	0,003	0,009	0,004	0,009	N/A	N/A
31th	0,032	0,086	0,038	0,101	N/A	N/A
32th	0,005	0,012	0,005	0,012	N/A	N/A
33th	0,003	0,009	0,004	0,010	N/A	N/A
34th	0,004	0,011	0,004	0,012	N/A	N/A
35th	0,025	0,067	0,027	0,073	N/A	N/A
36th	0,003	0,008	0,003	0,009	N/A	N/A
37th	0,026	0,070	0,028	0,075	N/A	N/A
38th	0,005	0,012	0,005	0,013	N/A	N/A
39th	0,004	0,010	0,004	0,011	N/A	N/A
40th	0,004	0,010	0,005	0,013	N/A	N/A
THD	2,28%		1,11%		23%	13%
PWHD	0,007%		0,003%		23%	22%

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99 Nr. 14TH0476-G99/1_1

Power Quality. Harmonics.						
SE27.6K						
Phase 2						
SSEG rating per phase (rpp)						
	At 45-55% of rated output 4,60kW		100% of rated output 8,79kW			
Harmonic	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Harmonic %	
					Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,049	0,130	0,125	0,352	8%	8%
3rd	0,211	0,561	0,299	0,839	21,6%	N/A
4th	0,050	0,134	0,097	0,274	4%	4%
5th	0,256	0,680	0,258	0,724	10,7%	10,7%
6th	0,038	0,101	0,056	0,159	2,67%	2,67%
7th	0,159	0,424	0,183	0,515	7,2%	7,2%
8th	0,013	0,035	0,018	0,049	2%	2%
9th	0,015	0,039	0,074	0,207	3,8%	N/A
10th	0,012	0,032	0,014	0,040	1,6%	1,6%
11th	0,130	0,346	0,116	0,327	3,1%	3,1%
12th	0,011	0,028	0,014	0,040	1,33%	1,33%
13th	0,105	0,280	0,142	0,400	2%	2%
14th	0,007	0,019	0,010	0,027	N/A	N/A
15th	0,012	0,031	0,016	0,044	N/A	N/A
16th	0,007	0,018	0,012	0,033	N/A	N/A
17th	0,080	0,212	0,100	0,280	N/A	N/A
18th	0,008	0,021	0,016	0,044	N/A	N/A
19th	0,067	0,178	0,062	0,174	N/A	N/A
20th	0,006	0,016	0,009	0,025	N/A	N/A
21th	0,012	0,032	0,013	0,036	N/A	N/A
22th	0,006	0,017	0,011	0,032	N/A	N/A
23th	0,055	0,146	0,059	0,164	N/A	N/A
24th	0,005	0,014	0,011	0,032	N/A	N/A
25th	0,046	0,123	0,039	0,109	N/A	N/A
26th	0,006	0,015	0,008	0,022	N/A	N/A
27th	0,009	0,025	0,012	0,032	N/A	N/A
28th	0,006	0,016	0,009	0,026	N/A	N/A
29th	0,038	0,102	0,036	0,100	N/A	N/A
30th	0,004	0,010	0,007	0,020	N/A	N/A
31th	0,033	0,089	0,030	0,083	N/A	N/A
32th	0,006	0,015	0,006	0,017	N/A	N/A
33th	0,007	0,017	0,006	0,017	N/A	N/A
34th	0,005	0,013	0,006	0,018	N/A	N/A
35th	0,027	0,073	0,029	0,080	N/A	N/A
36th	0,004	0,010	0,004	0,012	N/A	N/A
37th	0,027	0,073	0,024	0,066	N/A	N/A
38th	0,005	0,014	0,006	0,016	N/A	N/A
39th	0,005	0,013	0,003	0,008	N/A	N/A
40th	0,005	0,013	0,005	0,015	N/A	N/A
THD	2,88%		1,16%		23%	13%
PWHD	0,007%		0,003%		23%	22%

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Power Quality. Harmonics.

SE27.6K

Phase 3

SSEG rating per phase (rpp)						
	At 45-55% of rated output 4,56kW		100% of rated output 8,73kW			
Harmonic	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Measured Value (MV) in [A]	Measured Value (MV) in [%]	Harmonic %	
					Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,047	0,126	0,042	0,112	8%	8%
3rd	0,091	0,244	0,135	0,361	21,6%	N/A
4th	0,042	0,113	0,068	0,183	4%	4%
5th	0,429	1,149	0,303	0,811	10,7%	10,7%
6th	0,042	0,114	0,038	0,102	2,67%	2,67%
7th	0,304	0,813	0,129	0,345	7,2%	7,2%
8th	0,017	0,046	0,019	0,050	2%	2%
9th	0,042	0,113	0,054	0,144	3,8%	N/A
10th	0,011	0,029	0,016	0,042	1,6%	1,6%
11th	0,192	0,513	0,117	0,312	3,1%	3,1%
12th	0,012	0,032	0,012	0,032	1,33%	1,33%
13th	0,142	0,381	0,129	0,345	2%	2%
14th	0,012	0,032	0,011	0,029	N/A	N/A
15th	0,046	0,123	0,033	0,089	N/A	N/A
16th	0,008	0,020	0,010	0,025	N/A	N/A
17th	0,080	0,213	0,100	0,268	N/A	N/A
18th	0,008	0,020	0,009	0,025	N/A	N/A
19th	0,052	0,139	0,067	0,179	N/A	N/A
20th	0,006	0,016	0,007	0,019	N/A	N/A
21th	0,006	0,016	0,011	0,031	N/A	N/A
22th	0,005	0,014	0,007	0,019	N/A	N/A
23th	0,040	0,108	0,064	0,171	N/A	N/A
24th	0,005	0,012	0,006	0,017	N/A	N/A
25th	0,034	0,090	0,047	0,125	N/A	N/A
26th	0,005	0,015	0,005	0,014	N/A	N/A
27th	0,011	0,030	0,009	0,025	N/A	N/A
28th	0,005	0,014	0,006	0,017	N/A	N/A
29th	0,032	0,085	0,041	0,110	N/A	N/A
30th	0,003	0,009	0,004	0,010	N/A	N/A
31th	0,035	0,094	0,037	0,099	N/A	N/A
32th	0,005	0,012	0,005	0,013	N/A	N/A
33th	0,008	0,020	0,007	0,019	N/A	N/A
34th	0,005	0,012	0,005	0,013	N/A	N/A
35th	0,031	0,084	0,033	0,087	N/A	N/A
36th	0,003	0,008	0,003	0,009	N/A	N/A
37th	0,024	0,063	0,025	0,068	N/A	N/A
38th	0,004	0,011	0,005	0,013	N/A	N/A
39th	0,003	0,007	0,003	0,008	N/A	N/A
40th	0,004	0,011	0,005	0,013	N/A	N/A
THD	3,05%		1,18%		23%	13%
PWHD	0,008%		0,004%		23%	22%

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Power Quality. Power factor.				
SE25K				
Output power	216,2V	230V	253V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1,5\%$ of the stated level during the test.
20%	0,995	0,993	0,989	
50%	0,999	0,999	0,998	
75%	0,999	0,999	0,999	
100%	0,999	0,999	0,999	
Limit	>0,95	>0,95	>0,95	
SE27.6K				
Output power	216,2V	230V	253V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1,5\%$ of the stated level during the test.
20%	0,998	0,997	0,996	
50%	0,999	0,999	0,999	
75%	0,999	0,999	0,999	
100%	0,999	0,999	0,999	
Limit	>0,95	>0,95	>0,95	

Power Quality. Voltage fluctuation and Flicker.								
SE25K								
	Starting			Stopping			Running	
	dmax	dc	d(t)	dmax	dc	d(t)	Pst	Plt 2 hours
Measured values at test impedance	0,33%	3,3%	0,0%	0,33%	3,3%	0,0%	0,38	0,38
Normalised to standard impedance	0,30%	3,03%	0%	0,30%	3,03%	0%	0,0787	0,0787
Limits set under BS EN 61000-3-11	4%	3,3%	3,3% 500ms	4%	3,3%	3,3% 500ms	1,0	0,65
Test impedance	R	0,24* 0,4^	Ω	XI	0,15* 0,25	Ω		
Standard impedance	R	0,24* 0,4^	Ω	XI	0,15* 0,25^	Ω		

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Power Quality. DC injection.			
SE25K			
L1 phase			
Test level power [%]	10	55	100
Recorded value [mA]	13,99	10,39	14,43
Recorded value [%]	0,04	0,03	0,04
Limit [%]	0,25	0,25	0,25
L2 phase			
Test level power [%]	10	55	100
Recorded value [mA]	9,86	19,62	35,61
Recorded value [%]	0,03	0,03	0,01
Limit [%]	0,25	0,25	0,25
L3 phase			
Test level power [%]	10	55	100
Recorded value [mA]	3,75	19,80	35,86
Recorded value [%]	0,01	0,01	0,01
Limit [%]	0,25	0,25	0,25

Fault level Contribution.					
SE27.6K					
For a directly coupled SSEG			For a Inverter SSEG		
Parameter	Symbol	Value	Time after fault	Volts [V]	Amps [A]
Peak Short Circuit current	I_p	N/A	20ms	45,3	37,3
Initial Value of aperiodic current	A	N/A	100ms	45,3	37,3
Initial symmetrical short-circuit current*	I_k	N/A	250ms	44,2	37,0
Decaying (aperiodic) component of short circuit current*	i_{dc}	N/A	500ms	44,2	37,0
Reactance/Resistance Ratio of source*	X/R	N/A	Time to Trip [s]	0,507	

For rotating machines and linear piston machines the test should produce a 0s – 2s plot of the short circuit current as seen at the Generating Unit terminals.

* Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot.



Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 14TH0476-G99/1_1

Self Monitoring – Solid state switching.	N/A
It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0,5 seconds.	N/A (No solid state switching device)

Logic Interface (input port)	P
Confirm that an input port is provided and can be used to shut down the module.	Yes